



23 FEB 2024

ቀን _____
 Date _____
 ቁጥር AMOWE/07/01/1
 Ref. No. _____

To All Bidders

Ref: ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB

Subject: Clarification No.1 and Amendment No.1 to the RFBs

Subject to the clarification requested by some bidders, please find the clarification No.1 and amendment No.1 issued to the issued to the RFBs attached here with this letter.

Please be informed that other terms and condition specified in the RFB remains unchanged

With best Regards

Olkeba Bashe Gindaba
Chief Executive Officer

cc

- Office of the Minister
- Water supply and Sanitation Sector State Minister Office
- HoA GWRP WS PIT
- Procurement Executive Office

MoWE



T Clarification No. 1 issued to the RFBs

Query No.	Bid Ref	Clarification Requested	Response of Employer	The Clarification is applicable for
1	ET-MOWE-366013-CW-RFB	What is the Pump Motor diameter to install in 8" casings? Will the Cable price have included in the Electro Mechanical supply and Installation	The Pump diameter is < 185 MM to install in 8" casings. The price of supply and installation cable with the required length of 300 M as per the drawing should be included in the price	ET-MOWE-366013-CW-RFB
2	ET-MOWE-398355-CW-RFB	Table A. States Transformer installation and its accessories, while item No.3 Mentions Supply of Transformer at Sites. please clarify	the price to be offered should be for supply and Installation of Transformer and Accessories as the Scope of work is supply and Installation of Transformer and Accessories	Apply to ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB and ET-MOWE-366017-CW-RFB
3		From item No.2 -28 in table 8, related to supply and Installation of Submersible pumps, it is not clear whether the listed fittings are for installation, supply, or both.	The listed fittings are both for supply and installation.	
4	ET-MOWE-398361-CW-RFB	Is the client responsible for supplying pipes, fittings and Valves?	No. The price should include the Supply and Installation of pipes, fittings and Valves	Apply to ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB and ET-MOWE-366017-CW-RFB
		Table A. States Transformer installation and its accessories, while item No.3 Mentions Supply of Transformer at Sites. please clarify	As described S.No.2 above the price to be offered should be for supply and Installation of Transformer and Accessories as the Scope of work is supply and Installation of	



			Transformer and Accessories	
5		In column 6, the Top row stating the total price other than is unclear	Take it as a total price instead of what were described	
6		From item No.2 -28 in table 8, related to supply and Installation of Submersible pumps, it is not clear whether the listed fittings are for installation, supply, or both.	As described S.No.3 above, the listed fittings are both for supply and installation.	Apply to ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB and ET-MOWE-366017-CW-RFB
7	ET-MOWE-366013-CW-RFB	Can the Machine/equipment Required be filled through leasing	Yes. The Machinery and Equipment can be leased using the bidding formats included in the RFB	Apply for ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB
8		Is the Letter of Bid required to be included in both Technical and financial proposal	Both the Technical and financial proposal will be opened at a time as the bidding procedure is one Envelope. Hence, you can include the Letter of Bid in the Financial proposal	Apply for ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB
9	ET-MOWE-398355-CW-RFB	Is pre-bid meeting and Site visit mandatory	No. The bidder who wishes to attend the Pre-bid meeting and	Apply for ET-MOWE-398361-CW-RFB, ET-



			who wants to visit the site can make at their own will, and it is not mandatory requirement	MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB
	ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB	Is Joint Venture Mandatory with the Supplier	No. Bidders who are capable to fulfill the Evaluation and Qualification Criteria can submit as single entity. The Bidder should submit the Complete data sheet, Borchers and Compliance sheet as per the RFB to determine the substantial responsiveness of the Bid	Apply for ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB
	ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB	Is Manufacturing Authorization Mandatory?	The Manufacturing authorization is required for Oromia Lot I, II and III and Somali Lot I and II projects indicated in the Bid data sheet. However, for all sites the Bidder should submit the Complete data sheet, Borchers and Compliance sheet and other relevant documents as requested in the RFB as per the RFB to determine the substantial responsiveness of the Bid	Applicable for ET-MOWE-398361-CW-RFB, ET-MOWE-398355-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-402225-CW-RFB, ET-MOWE-366013-CW-RFB, ET-MOWE-366017-CW-RFB, ET-MOWE-402310-CW-RFB



Amendment No.1 Issued to The RFB

Query No.	Bid Ref	Previous stated as	Amended to
1	ET-MOWE-398361-CW-RFB	The Specified pump is expected to deliver a given head and flow using a power of less than or Equal to 70 KW	The Pump power is amended to less than or Equal to 75 KW instead of 70 KW

