

**Electromechanical Equipment and Pipes & Fittings for Gondar Town Water Supply
Project, ICB No: ET-MOWE-365121-GO-RFB
Responses to Request for Clarifications #3**

RFC #	Request for Clarifications	Responses
#1	The power cable length and power cable size in MM ² is not mentioned for the pumps. Please specify	The power cable size and length for six (6) submersible pumps are clearly specified in the bill of quantities. As an example, you can see Bill No.1 item no.1.1.1.2: - 4 core flat flexible copper conductor rubber insulation and rubber sheathed, 3 x 95mm ² + 50mm ² and length 250m.
#2	Please clarify whether the bid is only supply or supply with installation	Only supply
#3	We faced time shortage because we require more time to organize an offer that fully responds to all the requirements of electromechanical, pipes and fitting, pumps and accessories. Hence, we hereby kindly request the Ministry to extend the bid closing date by three weeks from the original closing date (11 th April 2024)	The time given for preparation of bids, which is 47 days is more than enough for this type of items. Thus, there is no further extension. Submit your bid with on or before 11 th April 2024
#4	As you well know all the European companies will be closing for the Easter holidays as of 29 March 2024 until April 2, 2024, we request you to give us one Week extension time so as to submit technically viable and financially competitive Bid	Same to #3 Above

CS

